




Center for Advanced Decision Support for
Water and Environmental Systems (CADSWES)
UNIVERSITY OF COLORADO BOULDER

Combining Optimization and Rulebased Simulation to Guide Grant County PUD Hydropower Operations

Mike Frantz – Grant County PUD
Mitch Clement, Tim Magee – CADSWES

RiverWare Use Group Meeting
August 29, 2019

Mid-Columbia Hydro System




7 Projects on Columbia River

- 2 Federal
 - Grand Coulee
 - Chief Joseph
- 5 Mid-C PUD's
 - Wells – Douglas PUD
 - Rocky Reach and Rock Island – Chelan PUD
 - Wanapum and Priest Rapids – Grant PUD

Mid-Columbia Operations

Mid-C Hourly Coordination Agreement

- Non-Fed Generation Requests aggregated and dispatched to projects by Central
- Formally ended in 2017
- Series of bridge agreements and extensions 2017-2019
- Currently only Chelan PUD and Grant PUD coordinating (4 Dams)
- Grant and Chelan scheduled to cutover to independent operations 11/19



Grant Independent (Two Dam) Operation

- ~15 Participants with slice ownership
- Each Participant sending a single generation request (every 4 seconds)
- Multiple downstream flow requirements
 - Minimums
 - Maximums
 - Flow Bands
- Changing value proposition for many Participants
 - Flexibility
- Each Participant is responding to different value propositions

Grant Independent Operation – Request/Return

1. Participants send a single Grant Request (not to each Project)
2. All Participant Requests are aggregated into a Total Request
3. Total Request is allocated to the two Projects
4. Each Participant is assigned a Total Return

Grant Independent Operation - Priorities

1. Meet Grant Constraints
2. Meet Participant 4-second Requests
3. Inform Participants of Resource
 - Maximums and Minimums
4. Inform Participants of Obligations
 - Planned
 - Emergent
5. Preserve Participant Resources
 - Maintain Flexibility
6. Isolate Participants to the extent possible


Grant Independent Operation – Operational “Tools”

1. Determine the split of Generation between Projects
2. Establishing Limits for Participants
3. Instigating Spill
4. Cutting Capacities to Participants

Grant RiverWare Models

- **Short Term Model:** Optimizaton
 - 1 Hour timestep
 - 3-5 days
 - Run 2x per hour
- **Real Time Model:** RBS – Iterative MRM
 - Single 1 Hour timestep
 - Run 1x per minute
- **Accounting Model:** Inline RBS and Accounting
 - 1 Hour timestep
 - ~ 1 month, last timestep is the previous hour
 - Run several times per day
 - After the fact accounting


RiverWare in Grant's Process



Short Term Model Purposes

- Calculate Constraints
 - Guidance Constraints – ensure formal constraints can be met in the future
 - Flexibility Constraints – maintain full up/down generating capacity for N hours
- Real Time Model Guidance
 - Guidance Constraints & Flexibility Constraints
 - Preferred Outflow Ratio (first timestep)
- Information to Participants
 - Maximum generating capability
 - Minimum generation requirements
- Expected Operations (secondary purpose)

ST Model



ST Model

RiverWare 7.5.2 - Grant ST Model

File Control Workspace Policy DMI Accounting Utilities Windows

Simulation

The main window displays a hydrological model diagram with various components and their validation status:

- Chief Joseph Data Validation (Valid)
- Chief Joseph (Invalid)
- Wells Data Validation (Valid)
- Wells (Invalid)
- Rocky Reach Data Validation (Valid)
- Rocky Reach (Invalid)
- Data Validation (Valid)
- Expected Flow Meet Requests (Invalid)
- Rock Island Data Validation (Valid)
- Rock Island (Invalid)
- Dates (Invalid)
- Expected Flow Expected Ops (Invalid)
- Wanapum Data Validation (Valid)
- Wanapum (Invalid)
- Expected Flow Min Gen 24 (Invalid)
- WAN to PRD (Invalid)
- Grant Data Validation (Valid)
- Grant (Invalid)
- Expected Flow Min Gen 8 (Invalid)
- Priest Rapids Data Validation (Valid)
- Priest Rapids (Invalid)
- Expected Flow Max Gen 24 (Invalid)
- Vernita Bar (Invalid)
- Expected Flow Max Gen 8 (Invalid)
- Expected Flow Guidance Constrai (Invalid)

Script Dashboard: Complete Run Sequence

File Edit

Complete Run Sequence

- ☒ Set Up Flow Scenarios
 - ☒ Set **Grant.Run Number's** value to **-1**
 - ☒ Set the controller to **Simulation**
 - ☒ Execute run
- ☒ Set to Expected Operations
- ☒ Set to Low Flow
- ☒ Execute Low Flow Expected Ops Run
 - ☒ Set Run Number to 1
 - ☒ Set the controller to **Simulation**
 - ☒ Execute run
 - ☒ Set the controller to **Optimization**
 - ☒ Execute run
 - ☒ Set the controller to **Rulebased Simulation**
 - ☒ Execute run
 - ☒ Store Results from Run 1 in Slot Cache
- ☐ Create Run 1 Snapshot
- ☒ Set Run Number to 2
- ☒ Set the controller to **Simulation**

Execution

▶ ■

Status: Ready Current Action: this script is no...

Object Viewer [Icons] [RBS] [Opt] RiverWare 11

Short Term Guidance Constraints

1. Low Flow Run: Storage Guidance Min

- Meet high priority (formal) constraints
- Trial objectives (no Freeze)
 - Minimize Storage at t_1
 - Minimize Storage at $t_2...$

2. High Flow Run: Storage Guidance Max


- Similar but Maximize Storage

3. Expected Flow Run

- Meet high priority (formal) constraints
- Apply Storage Guidance Min/Max Constraints
- Evaluate additional Guidance Constraints
 - Energy
 - Outflow

Guidance Constraints Example



Spawning Season – Limited Priest Rapids daytime Outflow



Flexibility Constraints

- One metric for flexibility: Number of hours with full upward and downward capacity
- Corollary:
 - Min Storage to generate at max for N hours before reaching formal min
 - Max Storage that allows min generation for N hours before forcing spill
- Model:
 - Calculate Min/Max Storage corresponding to N hours
 - Add constraints: $\text{Min}_N \leq \text{Storage} \leq \text{Max}_N$

Flexibility Constraints Example



Flexibility Constraints Implementation

- Initialization Rules: Calculate Storage Min/Max for N hours
- Optimization:
 - Trial objective (no Freeze): $\text{Min}_{N,t} \leq \text{Storage}_t \leq \text{Max}_{N,t}$
 - For each t
 - IF trial constraint was satisfied
Apply $\text{Min}_{N,t}$, $\text{Max}_{N,t}$ with a Freeze
 - ELSE
Omit the constraint
 - Repeat for $N + 1$
- Post-opt Rules: Report highest level satisfied

RT Model Purpose

- Guidance to EMS – how to allocate generation in real time
- RT Output Table
Populated with Iterative MRM
- EMS interpolates using real-time (4 sec) generation request

RT Output Table

Value: 0

	Request MW			Wanapum Gen MW			Priest Rapids Gen MW		
1	0.00	I	0	0.00	I	0	0.00	I	0
2	90.01	i	0	0.00	i	0	90.01	i	0
3	93.84	i	0	0.00	i	0	93.84	i	0
4	185.35	i	0	91.51	i	0	93.84	i	0
5	275.87	i	0	182.03	i	0	93.84	i	0
6	364.97	i	0	271.14	i	0	93.84	i	0
7	445.09	i	0	271.44	i	0	173.65	i	0
8	532.11	i	0	358.46	i	0	173.65	i	0
9	617.64	i	0	358.91	i	0	258.74	i	0
10	701.76	i	0	443.03	i	0	258.74	i	0
11	784.53	i	0	443.44	i	0	341.09	i	0
12	866.30	i	0	525.21	i	0	341.09	i	0
13	945.17	i	0	525.51	i	0	419.65	i	0
14	1,021.24	i	0	601.59	i	0	419.65	i	0
15	1,097.46	i	0	601.92	i	0	495.53	i	0
16	1,163.41	i	0	667.88	i	0	495.53	i	0
17	1,176.32	i	0	680.79	i	0	495.53	i	0
18	1,187.40	i	0	655.90	i	0	531.50	i	0
19	1,189.14	i	0	693.60	i	0	495.53	i	0
20	1,201.86	i	0	706.32	i	0	495.53	i	0
21	1,274.10	i	0	706.67	i	0	567.43	i	0
22	1,287.41	i	0	706.74	i	0	580.67	i	0
23	1,300.51	i	0	706.81	i	0	593.70	i	0
24	1,313.48	i	0	706.88	i	0	606.60	i	0
25	1,326.35	i	0	706.95	i	0	619.40	i	0
26	1,339.13	i	0	707.02	i	0	632.11	i	0
27	1,351.81	i	0	707.09	i	0	644.73	i	0
28	1,364.40	i	0	707.15	i	0	657.25	i	0
29	1,390.87	i	0	715.72	i	0	675.15	i	0
30	1,435.08	i	0	725.05	i	0	710.03	i	0
31	1,742.40	i	0	893.25	i	0	849.15	i	0

RT Iterative MRM

- For each run:
 - Operate to target Turbine Rel.
 - Rules check higher priorities
 - Calculate resulting Power
- Runs 1-3
 - Formal minimums
 - ST Guidance Constraint Mins
 - Flexibility Minimums

RT Output Table

Value: 0 MW

	Request MW			Wanapum Gen MW			Priest Rapids Gen MW		
1	0.00	i	0	0.00	i	0	0.00	i	0
2	90.01	i	0	0.00	i	0	90.01	i	0
3	93.84	i	0	0.00	i	0	93.84	i	0
4	185.35	i	0	91.51	i	0	93.84	i	0
5	NaN	O	0	NaN	O	0	NaN	O	0
6	NaN	O	0	NaN	O	0	NaN	O	0
7	NaN	O	0	NaN	O	0	NaN	O	0
8	NaN	O	0	NaN	O	0	NaN	O	0
9	NaN	O	0	NaN	O	0	NaN	O	0
10	NaN	O	0	NaN	O	0	NaN	O	0
11	NaN	O	0	NaN	O	0	NaN	O	0
12	NaN	O	0	NaN	O	0	NaN	O	0
13	NaN	O	0	NaN	O	0	NaN	O	0
14	NaN	O	0	NaN	O	0	NaN	O	0
15	NaN	O	0	NaN	O	0	NaN	O	0
16	NaN	O	0	NaN	O	0	NaN	O	0
17	NaN	O	0	NaN	O	0	NaN	O	0
18	NaN	O	0	NaN	O	0	NaN	O	0
19	NaN	O	0	NaN	O	0	NaN	O	0
20	NaN	O	0	NaN	O	0	NaN	O	0
21	NaN	O	0	NaN	O	0	NaN	O	0
22	NaN	O	0	NaN	O	0	NaN	O	0
23	NaN	O	0	NaN	O	0	NaN	O	0
24	NaN	O	0	NaN	O	0	NaN	O	0
25	NaN	O	0	NaN	O	0	NaN	O	0
26	NaN	O	0	NaN	O	0	NaN	O	0
27	NaN	O	0	NaN	O	0	NaN	O	0
28	NaN	O	0	NaN	O	0	NaN	O	0
29	NaN	O	0	NaN	O	0	NaN	O	0
30	NaN	O	0	NaN	O	0	NaN	O	0
31	NaN	O	0	NaN	O	0	NaN	O	0

RT Iterative MRM

- For each run:
 - Operate to target Turbine Rel.
 - Rules check higher priorities
 - Calculate resulting Power
- Runs 1-3
 - Formal minimums
 - ST Guidance Constraint Mins
 - Flexibility Minimums
- Runs 4-6
 - Similar for Max

RT Output Table

Value: 0 MW

	Request MW			Wanapum Gen MW			Priest Rapids Gen MW		
1	0.00	I	0	0.00	I	0	0.00	I	0
2	90.01	i	0	0.00	i	0	90.01	i	0
3	93.84	i	0	0.00	i	0	93.84	i	0
4	185.35	i	0	91.51	i	0	93.84	i	0
5	NaN	O	0	NaN	O	0	NaN	O	0
6	NaN	O	0	NaN	O	0	NaN	O	0
7	NaN	O	0	NaN	O	0	NaN	O	0
8	NaN	O	0	NaN	O	0	NaN	O	0
9	NaN	O	0	NaN	O	0	NaN	O	0
10	NaN	O	0	NaN	O	0	NaN	O	0
11	NaN	O	0	NaN	O	0	NaN	O	0
12	NaN	O	0	NaN	O	0	NaN	O	0
13	NaN	O	0	NaN	O	0	NaN	O	0
14	NaN	O	0	NaN	O	0	NaN	O	0
15	NaN	O	0	NaN	O	0	NaN	O	0
16	NaN	O	0	NaN	O	0	NaN	O	0
17	NaN	O	0	NaN	O	0	NaN	O	0
18	NaN	O	0	NaN	O	0	NaN	O	0
19	NaN	O	0	NaN	O	0	NaN	O	0
20	NaN	O	0	NaN	O	0	NaN	O	0
21	NaN	O	0	NaN	O	0	NaN	O	0
22	NaN	O	0	NaN	O	0	NaN	O	0
23	NaN	O	0	NaN	O	0	NaN	O	0
24	NaN	O	0	NaN	O	0	NaN	O	0
25	NaN	O	0	NaN	O	0	NaN	O	0
26	NaN	O	0	NaN	O	0	NaN	O	0
27	NaN	O	0	NaN	O	0	NaN	O	0
28	NaN	O	0	NaN	O	0	NaN	O	0
29	1,390.87	i	0	715.72	i	0	675.15	i	0
30	1,435.08	i	0	725.05	i	0	710.03	i	0
31	1,742.40	i	0	893.25	i	0	849.15	i	0

RT Iterative MRM

Discretionary Range

(within flexibility constraints)

- Execute 2 “trial” runs
 1. Increase Wanapum Turbine Release by 1 unit

RT Output Table									
		Value: 0		MW					
	Request MW			Wanapum Gen MW			Priest Rapids Gen MW		
1	0.00	I	0	0.00	I	0	0.00	I	0
2	90.01	i	0	0.00	i	0	90.01	i	0
3	93.84	i	0	0.00	i	0	93.84	i	0
4	185.35	i	0	91.51	i	0	93.84	i	0
5	NaN	O	0	NaN	O	0	NaN	O	0
6	NaN	O	0	NaN	O	0	NaN	O	0
7	NaN	O	0	NaN	O	0	NaN	O	0
8	NaN	O	0	NaN	O	0	NaN	O	0
9	NaN	O	0	NaN	O	0	NaN	O	0
10	NaN	O	0	NaN	O	0	NaN	O	0
11	NaN	O	0	NaN	O	0	NaN	O	0
12	NaN	O	0	NaN	O	0	NaN	O	0
13	NaN	O	0	NaN	O	0	NaN	O	0
14	NaN	O	0	NaN	O	0	NaN	O	0
15	NaN	O	0	NaN	O	0	NaN	O	0
16	NaN	O	0	NaN	O	0	NaN	O	0
17	NaN	O	0	NaN	O	0	NaN	O	0
18	NaN	O	0	NaN	O	0	NaN	O	0
19	NaN	O	0	NaN	O	0	NaN	O	0
20	NaN	O	0	NaN	O	0	NaN	O	0
21	NaN	O	0	NaN	O	0	NaN	O	0
22	NaN	O	0	NaN	O	0	NaN	O	0
23	NaN	O	0	NaN	O	0	NaN	O	0
24	NaN	O	0	NaN	O	0	NaN	O	0
25	NaN	O	0	NaN	O	0	NaN	O	0
26	NaN	O	0	NaN	O	0	NaN	O	0
27	NaN	O	0	NaN	O	0	NaN	O	0
28	NaN	O	0	NaN	O	0	NaN	O	0
29	1,390.87	i	0	715.72	i	0	675.15	i	0
30	1,435.08	i	0	725.05	i	0	710.03	i	0
31	1,742.40	i	0	893.25	i	0	849.15	i	0

RT Iterative MRM

Discretionary Range

(within flexibility constraints)

- Execute 2 “trial” runs
 1. Increase Wanapum Turbine Release by 1 unit
 2. Increase Priest Rapids Turbine Release by 1 unit

Value: 0		MW	
	Request MW	Wanapum Gen MW	Priest Rapids Gen MW
1	0.00 I 0	0.00 I 0	0.00 I 0
2	90.01 i 0	0.00 i 0	90.01 i 0
3	93.84 i 0	0.00 i 0	93.84 i 0
4	185.35 i 0	91.51 i 0	93.84 i 0
5	NaN O 0	NaN O 0	NaN O 0
6	NaN O 0	NaN O 0	NaN O 0
7	NaN O 0	NaN O 0	NaN O 0
8	NaN O 0	NaN O 0	NaN O 0
9	NaN O 0	NaN O 0	NaN O 0
10	NaN O 0	NaN O 0	NaN O 0
11	NaN O 0	NaN O 0	NaN O 0
12	NaN O 0	NaN O 0	NaN O 0
13	NaN O 0	NaN O 0	NaN O 0
14	NaN O 0	NaN O 0	NaN O 0
15	NaN O 0	NaN O 0	NaN O 0
16	NaN O 0	NaN O 0	NaN O 0
17	NaN O 0	NaN O 0	NaN O 0
18	NaN O 0	NaN O 0	NaN O 0
19	NaN O 0	NaN O 0	NaN O 0
20	NaN O 0	NaN O 0	NaN O 0
21	NaN O 0	NaN O 0	NaN O 0
22	NaN O 0	NaN O 0	NaN O 0
23	NaN O 0	NaN O 0	NaN O 0
24	NaN O 0	NaN O 0	NaN O 0
25	NaN O 0	NaN O 0	NaN O 0
26	NaN O 0	NaN O 0	NaN O 0
27	NaN O 0	NaN O 0	NaN O 0
28	NaN O 0	NaN O 0	NaN O 0
29	1,390.87 i 0	715.72 i 0	675.15 i 0
30	1,435.08 i 0	725.05 i 0	710.03 i 0
31	1,742.40 i 0	893.25 i 0	849.15 i 0

RT Iterative MRM

Discretionary Range

(within flexibility constraints)

- Execute 2 “trial” runs
 1. Increase Wanapum Turbine Release by 1 unit
 2. Increase Priest Rapids Turbine Release by 1 unit
- Iterative MRM rules select result closest to ST Outflow Ratio

RT Output Table

Value: 0

MW

	Request MW		Wanapum Gen MW		Priest Rapids Gen MW
1	0.00	I 0	0.00	I 0	0.00
2	90.01	i 0	0.00	i 0	90.01
3	93.84	i 0	0.00	i 0	93.84
4	185.35	i 0	91.51	i 0	93.84
5	275.87	i 0	182.03	i 0	93.84
6	NaN	O 0	NaN	O 0	NaN
7	NaN	O 0	NaN	O 0	NaN
8	NaN	O 0	NaN	O 0	NaN
9	NaN	O 0	NaN	O 0	NaN
10	NaN	O 0	NaN	O 0	NaN
11	NaN	O 0	NaN	O 0	NaN
12	NaN	O 0	NaN	O 0	NaN
13	NaN	O 0	NaN	O 0	NaN
14	NaN	O 0	NaN	O 0	NaN
15	NaN	O 0	NaN	O 0	NaN
16	NaN	O 0	NaN	O 0	NaN
17	NaN	O 0	NaN	O 0	NaN
18	NaN	O 0	NaN	O 0	NaN
19	NaN	O 0	NaN	O 0	NaN
20	NaN	O 0	NaN	O 0	NaN
21	NaN	O 0	NaN	O 0	NaN
22	NaN	O 0	NaN	O 0	NaN
23	NaN	O 0	NaN	O 0	NaN
24	NaN	O 0	NaN	O 0	NaN
25	NaN	O 0	NaN	O 0	NaN
26	NaN	O 0	NaN	O 0	NaN
27	NaN	O 0	NaN	O 0	NaN
28	NaN	O 0	NaN	O 0	NaN
29	1,390.87	i 0	715.72	i 0	675.15
30	1,435.08	i 0	725.05	i 0	710.03
31	1,742.40	i 0	893.25	i 0	849.15

<

>

RT Iterative MRM

Discretionary Range

(within flexibility constraints)

- Execute 2 “trial” runs
 1. Increase Wanapum Turbine Release by 1 unit
 2. Increase Priest Rapids Turbine Release by 1 unit
- Iterative MRM rules select result closest to ST Outflow Ratio
- Repeat

RT Output Table

Value: 0 MW


	Request MW			Wanapum Gen MW			Priest Rapids Gen MW		
1	0.00	I	0	0.00	I	0	0.00	I	0
2	90.01	i	0	0.00	i	0	90.01	i	0
3	93.84	i	0	0.00	i	0	93.84	i	0
4	185.35	i	0	91.51	i	0	93.84	i	0
5	275.87	i	0	182.03	i	0	93.84	i	0
6	364.97	i	0	271.14	i	0	93.84	i	0
7	NaN	O	0	NaN	O	0	NaN	O	0
8	NaN	O	0	NaN	O	0	NaN	O	0
9	NaN	O	0	NaN	O	0	NaN	O	0
10	NaN	O	0	NaN	O	0	NaN	O	0
11	NaN	O	0	NaN	O	0	NaN	O	0
12	NaN	O	0	NaN	O	0	NaN	O	0
13	NaN	O	0	NaN	O	0	NaN	O	0
14	NaN	O	0	NaN	O	0	NaN	O	0
15	NaN	O	0	NaN	O	0	NaN	O	0
16	NaN	O	0	NaN	O	0	NaN	O	0
17	NaN	O	0	NaN	O	0	NaN	O	0
18	NaN	O	0	NaN	O	0	NaN	O	0
19	NaN	O	0	NaN	O	0	NaN	O	0
20	NaN	O	0	NaN	O	0	NaN	O	0
21	NaN	O	0	NaN	O	0	NaN	O	0
22	NaN	O	0	NaN	O	0	NaN	O	0
23	NaN	O	0	NaN	O	0	NaN	O	0
24	NaN	O	0	NaN	O	0	NaN	O	0
25	NaN	O	0	NaN	O	0	NaN	O	0
26	NaN	O	0	NaN	O	0	NaN	O	0
27	NaN	O	0	NaN	O	0	NaN	O	0
28	NaN	O	0	NaN	O	0	NaN	O	0
29	1,390.87	i	0	715.72	i	0	675.15	i	0
30	1,435.08	i	0	725.05	i	0	710.03	i	0
31	1,742.40	i	0	893.25	i	0	849.15	i	10

RT Iterative MRM

Discretionary Range

(within flexibility constraints)

- Execute 2 “trial” runs
 1. Increase Wanapum Turbine Release by 1 unit
 2. Increase Priest Rapids Turbine Release by 1 unit
- Iterative MRM rules select result closest to ST Outflow Ratio
- Repeat



	Request MW	Wanapum Gen MW	Priest Rapids Gen MW
1	0.00 I 0	0.00 I 0	0.00 I 0
2	90.01 i 0	0.00 i 0	90.01 i 0
3	93.84 i 0	0.00 i 0	93.84 i 0
4	185.35 i 0	91.51 i 0	93.84 i 0
5	275.87 i 0	182.03 i 0	93.84 i 0
6	364.97 i 0	271.14 i 0	93.84 i 0
7	445.09 i 0	271.44 i 0	173.65 i 0
8	NaN O 0	NaN O 0	NaN O 0
9	NaN O 0	NaN O 0	NaN O 0
10	NaN O 0	NaN O 0	NaN O 0
11	NaN O 0	NaN O 0	NaN O 0
12	NaN O 0	NaN O 0	NaN O 0
13	NaN O 0	NaN O 0	NaN O 0
14	NaN O 0	NaN O 0	NaN O 0
15	NaN O 0	NaN O 0	NaN O 0
16	NaN O 0	NaN O 0	NaN O 0
17	NaN O 0	NaN O 0	NaN O 0
18	NaN O 0	NaN O 0	NaN O 0
19	NaN O 0	NaN O 0	NaN O 0
20	NaN O 0	NaN O 0	NaN O 0
21	NaN O 0	NaN O 0	NaN O 0
22	NaN O 0	NaN O 0	NaN O 0
23	NaN O 0	NaN O 0	NaN O 0
24	NaN O 0	NaN O 0	NaN O 0
25	NaN O 0	NaN O 0	NaN O 0
26	NaN O 0	NaN O 0	NaN O 0
27	NaN O 0	NaN O 0	NaN O 0
28	NaN O 0	NaN O 0	NaN O 0
29	1,390.87 i 0	715.72 i 0	675.15 i 0
30	1,435.08 i 0	725.05 i 0	710.03 i 0
31	1,742.40 i 0	893.25 i 0	849.15 i 10

RT Iterative MRM

Discretionary Range

(within flexibility constraints)

- Execute 2 “trial” runs
 1. Increase Wanapum Turbine Release by 1 unit
 2. Increase Priest Rapids Turbine Release by 1 unit
- Iterative MRM rules select result closest to ST Outflow Ratio
- Repeat

RT Output Table

Value: 0 MW

	Request MW		Wanapum Gen MW		Priest Rapids Gen MW
1	0.00	I 0	0.00	I 0	0.00 I 0
2	90.01	i 0	0.00	i 0	90.01 i 0
3	93.84	i 0	0.00	i 0	93.84 i 0
4	185.35	i 0	91.51	i 0	93.84 i 0
5	275.87	i 0	182.03	i 0	93.84 i 0
6	364.97	i 0	271.14	i 0	93.84 i 0
7	445.09	i 0	271.44	i 0	173.65 i 0
8	532.11	i 0	358.46	i 0	173.65 i 0
9	617.64	i 0	358.91	i 0	258.74 i 0
10	701.76	i 0	443.03	i 0	258.74 i 0
11	784.53	i 0	443.44	i 0	341.09 i 0
12	866.30	i 0	525.21	i 0	341.09 i 0
13	945.17	i 0	525.51	i 0	419.65 i 0
14	1,021.24	i 0	601.59	i 0	419.65 i 0
15	1,097.46	i 0	601.92	i 0	495.53 i 0
16	1,163.41	i 0	667.88	i 0	495.53 i 0
17	1,176.32	i 0	680.79	i 0	495.53 i 0
18	1,187.40	i 0	655.90	i 0	531.50 i 0
19	1,189.14	i 0	693.60	i 0	495.53 i 0
20	1,201.86	i 0	706.32	i 0	495.53 i 0
21	1,274.10	i 0	706.67	i 0	567.43 i 0
22	1,287.41	i 0	706.74	i 0	580.67 i 0
23	1,300.51	i 0	706.81	i 0	593.70 i 0
24	1,313.48	i 0	706.88	i 0	606.60 i 0
25	1,326.35	i 0	706.95	i 0	619.40 i 0
26	1,339.13	i 0	707.02	i 0	632.11 i 0
27	1,351.81	i 0	707.09	i 0	644.73 i 0
28	1,364.40	i 0	707.15	i 0	657.25 i 0
29	1,390.87	i 0	715.72	i 0	675.15 i 0
30	1,435.08	i 0	725.05	i 0	710.03 i 0
31	1,742.40	i 0	893.25	i 0	849.15 i 0

Current Work

- ST Model:
Special logic to prepare for a capacity imbalance – maintain a percentage of full capacity
- RT Model:
Cases to use criteria other than ST Outflow Ratio
Possibly convert to 5 Minute timestep
- Cutover to Independent Operations:
November 2019