

Universidad
Autónoma de
Zacatecas



EVALUATION OF SURFACE WATER SOURCES FOR DOMESTIC SUPPLY IN THE FRESNILLO - GUADALUPE INDUSTRIAL COMPLEX.

RiverWare User Group Meeting

Dr. Ángel Alfonso Villalobos de Alba¹, Dra. Alba Nélida
García Beltrán¹, M.I. Hansell Omar López Cazares²


1 Profesor Investigador, Universidad Autónoma de Zacatecas

2. Egresado, Universidad Autónoma de Zacatecas



ZACATECAS, ZACATECAS, 22 DE ENERO DE 2018

Zacatecas city and its surrounding urban areas have serious problems with its **drinking water supply**. The main source of supply is with groundwater. Currently, the water supply agency has to **pumped from more than 100 m deep** in part of the aquifer, which has caused **some wells to not meet the quality parameters to be potable**.

Introduction: Target population




STUDY AREA



The study area is located in the western part of Zacatecas state, it includes the municipalities of Chalchihuites, Jiménez de Teul, Sombrerete and Valparaíso.


Milpillas Dam

As a result of the studies of feasibility : there is an alternative that involve Milpillas Dam and an acueduct of 180 km length to supply a demand of 1.3 m³/s.



- ❖ Milpillas Dam simulation
- ❖ San Andrés- Milpillas system:
Determine the transfer flow from San Andrés to Milpillas
- ❖ Relocate Milpillas Dam to “El Infierno” site.

AVERAGE ANNUAL RUNOFF



San Andrés and El Infierno subbasins are not gauged, so the runoffs were estimated.

BASIN	ANNUAL AVERAGE RUNOFF(Hm ³)	MONTHLY AVERAGE RUNOFF (Hm ³)
Milpillas	62.30	5.19
San Andrés Cuenca Propia	28.91	2.41
EL Infierno Cuenca Propia	41.60	3.47
San Andrés Completa	91.21	7.60
El Infierno Completa	103.89	8.66

Information used for reservoir simulation




- Inflows for each sub-basin
- Evaporation coefficients of the study area
- Volume-Elevation-Area Tables (E-V-A)
- Demands for supply drinking water
- Minimum ecological flow in each reservoir

The inflows series for the simulation have a period of 59 years. This information will be necessary to carry out the simulations in RiverWare.

- The simulation begins in September 1954,
- There is a monthly time step model for each case, 708 months to evaluate.

A rule-based simulation was used.

Case 1: MILPILLAS reservoir



Results: Case 1

Simulation start at full capacity: 59.604 Hm³.

Milpillas demand (m ³ /s)	Inflow (Hm ³)	Demands (Mm ³)		Outflows (Mm ³)				Shortage%		System efficiency%	Supply guaranty . (%)		
		Ecological flow	Drinking water	Ecol Flow	Drinking Water	Spill	Evaporation	Ecol flow%	Drinking water %		Ecological flow	Drinking water	Total
1.2	3,676.57	367.54	2,232.75	363.45	2,055.87	1,199.81	81.11	1.11	7.92	65.38	98.89	92.08	93.04
1.3	3,676.57	367.54	2,418.81	363.18	2,163.84	1,098.89	74.87	1.19	10.54	68.28	98.81	89.46	90.69
1.4	3,676.57	367.54	2,604.87	360.75	2,269.21	1,001.57	69.78	1.85	12.89	71.05	98.15	87.11	88.48
1.5	3,676.57	367.54	2,790.94	359.8	2,368.14	908.69	65.2	2.11	15.15	73.69	97.89	84.85	86.37
1.6	3,676.57	367.54	2,977.00	359.28	2,454.42	827.03	61.63	2.25	17.55	76	97.75	82.45	84.13


Case 2: Milpillas - San Andrés system

Since Milpillas can not guarantee the demand throughout the period, it seeks to complete the supply with San Andrés.

Some analyzes are carried out to determine the volume of water that the San Andrés dam can provide.

2a. Constant transfer flow

2b. Transfer flow f (Milpillas Empty space)



Case 2a. (Constant) Transfer flow from San Andrés to Milpillas



Milpillas demand of 1.3 m³/s, both reservoirs starts at full capacity

	Capacidad Útil (m ³)	Elevación máxima (m)	Altura de la cortina (m)
Milpillas	59,604,109.63	2,053.605	83.6
San Andrés	92,091,582.91	1,882	110

Different simulations were carried out varying the constant monthly demand of San Andrés, from 0.4 m³ / s to 0.7 m³ / s


San Andrés demand (m ³ /s)	Total Inflow (Mm ³)	Available water (Mm ³)	Total demand (Mm ³)		Outputs (Mm ³)				Shortage %		System efficiency %	Supply guaranty . (%)		
			Ecologigal Flow SA	Drinking water	Ecological SA	Drinking W Milpillas	Spill SA	Evaporated	Ecologycal SA %	Drinking Water Milpillas %		Ecologycal	Drinking water	Total
0.2	5,383.04	5,405.48	170.59	2,418.81	170.59	2,299.42	2,707.30	228.17	0	4.94	45.69	100	95.06	95.39
0.25	5,383.04	5,405.31	170.59	2,418.81	170.59	2,326.19	2,678.97	229.56	0	3.83	46.19	100	96.17	96.42
0.3	5,383.04	5,405.34	170.59	2,418.81	170.59	2,358.74	2,643.33	232.68	0	2.48	46.79	100	97.52	97.68
0.35	5,383.04	5,404.88	170.59	2,418.81	170.59	2,378.62	2,622.16	233.51	0	1.66	47.17	100	98.34	98.45
0.4	5,383.04	5,402.19	170.59	2,418.81	170.59	2,395.08	2,601.37	235.15	0	0.98	47.49	100	99.02	99.08
0.45	5,383.04	5,397.77	170.59	2,418.81	170.59	2,407.36	2,583.45	236.36	0	0.47	47.76	100	99.53	99.56
0.5	5,383.04	5,397.70	170.59	2,418.81	170.59	2,415.59	2,575.00	236.52	0	0.13	47.91	100	99.87	99.88
0.6	5,383.04	5,401.72	170.59	2,418.81	170.59	2,418.81	2,575.55	236.77	0	0	47.94	100	100	100
0.7	5,383.04	5,402.41	170.59	2,418.81	170.59	2,418.81	2,575.97	237.04	0	0	47.93	100	100	100

System efficiency < 50 %



Deficit in drinking and ecological demands, Milpillas, E2a.

Deficit in drinking and ecological demands, San Andrés, E2a.



Milpillas and San Andrés storages variation, E2a.

Case 2b.

The aim was to find the necessary factors to obtain a minimum deficit and an optimal storage for both reservoirs.


Milpillas demand from 1.3 m³/s hasta 2.7 m³/s

Reserve volumen (number of months).


System efficiency: 79.1 %

San Andrés Max demand (m ³ /s)	Inflows system (Hm ³)	Available Water (Hm ³)	Demands in simulated period(Hm ³)			Outflows(Hm ³)				Shortages %		% Efficiency	Supply garanty . (%)		
			Ecologycal Flow SA	Drinking Water	Total	Ecologycal Flow	Drinking Water Milpillas	Spill SA	Evaporated Volume	Ecologycal Flow%	Drinking water %		Ecologycal Flow	Drinking wáter %	Total
2.564	5,383.04	5,481.99	170.59	4,651.56	4,822.15	170.56	3,932.66	1,232.65	146.12	0.02	15.46	74.85	99.98	84.54	85.09
2.862	5,312.25	5,445.96	167.99	4,579.42	4,747.41	167.46	4,109.52	1,033.64	135.34	0.32	10.26	78.53	99.68	89.74	90.09
3.084	5,312.25	5,444.16	167.99	4,579.42	4,747.41	167.46	4,130.91	1,033.64	144.62	0.32	9.79	78.95	99.68	90.21	90.54
3.283	5,312.25	5,445.96	167.99	4,579.42	4,747.41	167.51	4,134.28	1,002.07	142.10	0.29	9.72	78.99	99.71	90.28	90.61
4.682	5,312.25	5,445.96	167.99	4,579.42	4,747.41	167.51	4,134.60	999.08	144.77	0.29	9.71	79.00	99.71	90.29	90.62
4.673	5,312.25	5,445.96	167.99	4,579.42	4,747.41	167.36	4,140.27	990.45	147.88	0.38	9.59	79.10	99.62	90.41	90.74
7.842	5,312.25	5,445.96	167.99	4,579.42	4,747.41	167.38	4,137.35	991.71	149.52	0.37	9.65	79.04	99.63	90.35	90.68
11.731	5,312.25	5,445.96	167.99	4,579.42	4,747.41	167.38	4,130.73	999.63	148.21	0.37	9.80	78.92	99.63	90.20	90.54

These results show the maximum demand requested in San Andrés, so Milpillas can supply 2.7 m³ / s



Shortages in Milpillas, 2b.




Shortages in San Andrés, 2b



Milpillas and San Andrés storages, 2b.

Case 3. El Infierno site Simulation




Dam	Storage capacity(m ³)	Pool elevation (m)	hight dam (m)
Infierno	326,360,700	1,830.00	139

Case 3. Results


Water Volume requested to el Infierno from 1.3 m³/s to 3.0 m³/s,

Infierno Demand (m ³ /s)	Available Water (Mm ³)	Demands (Mm ³)		Outputs (Mm ³)				Shortages %		Efficiency system %	Garanty. (%)		
		Ecologycal flow	Drinking Water	Ecologycal flow	Drinking Water	Spill	Evaporated	Ecologycal flow	Drinking Water		Ecologycal flow	Drinking Water	Total
2.6	6,401.31	612.98	4,837.62	609.59	4,651.44	891.87	248.41	0.55	3.85	82.19	99.45	96.15	96.52
2.8	6,402.37	612.98	5,209.75	609.33	4,881.05	683.23	228.75	0.6	6.31	85.76	99.4	93.69	94.29
3	6,403.42	612.98	5,581.87	603.81	5,042.11	550.11	207.39	1.5	9.67	88.17	98.5	90.33	91.14
3.17	6,404.32	612.98	5,898.18	602.33	5,171.90	441.51	188.58	1.74	12.31	90.16	98.26	87.69	88.68


For demand = 3m³/s, system efficiency =88.17 %



Déficit en la demanda de usuario en Infierno, E3.



Déficit en la demanda de caudal ecológico en Infierno, E3.



Variación del embalse del Infierno, E3.

Summary of Results

Case	Elevation Dam (m)	Storage capacity (Hm ³)	Demand Max San Andres (m ³ /s)	Demand Max Infierno (m ³ /s)	Reserve volume Milpillars	Milpillars Demand (m ³ /s)	Inflow volume	Available water Hm3	Demands (Hm ³)		
									Ecologycal flow	Drinking water	Total
1	2052	59.60	n/a	n/a	n/a	1.30	3,676.570	3736.1695	367.54	2,418.81	2,2786.35
2a	2052-1879	151.70	0.60	n/a	n/a	1.30	5,383.041	5,401.72	170.59	2,418.81	2,589.41
2b	2052-1880	151.70	4.67	n/a	6	2.50	5,312.255	5,445.96	167.99	4,579.42	4,747.41
3	2052-1830	151.70	5.61	n/a	n/a	2.50	5,383.041	5,479.88	170.59	4,651.56	4,822.15

Outflows (Hm ³)				Shortages		%Efficiency	Garanty (%)		
Ecologycal flow	Drinking water	Spill	Evaporado sistema	Ecologycal flow	Drinking water		Ecologycal flow	Drinking water	Total
363.45	2,163.87	1,098.89	74.87	1.19	10.64	68.28	98.81	89.46	90.69
170.59	2,418.81	2,575.55	236.77	0.00	0.00	47.94	100.00	100.00	100.00
167.36	4,140.27	990.45	147.88	0.38	9.59	79.10	99.62	90.41	90.74
169.14	4,232.01	980.81	158.59	0.85	9.02	88.17	98.5	90.33	91.14

Conclusions

The objective of the project is to stop using the underground water to recover the piezometric levels and the aquifer's water quality.

Milpillas capacity can not be increase due to topographical conditions.

Case 1: Release 1.3, system efficiency 68.28%

Case 2a: Release 1.3, system efficiency 47.94%

Case 2b: Release 2.7, system efficiency 79.1%

Case 3: Release 3.0, system efficiency 88.14%

The best option is “El Infierno” site since more water can be extracted for the Fresnillo-Guadalupe industrial complex and the price of cubic meter of water is reduced around 20%. This option also presents deficits, but they can be mitigated by making joint use of surface and underground water.